



**Govt. of Maharashtra**  
**Directorate of Maharashtra Fire Service**  
Vidyanagri, Hans Bhugra Marg, Santacruz (East),  
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666  
www.mahafireservice.gov.in

**FORM N**  
**[ ( See section 9 (3) and rule 14 )**  
**License to act as a License Agency for the purpose of**  
**Fire Prevention and Life Safety Measure**

License No. MFS / LA / F-04

Date: 04.01.2025

License is hereby granted under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Shri Sairaj Enterprises** having their registered office at **Y Corner, Near Kranti nagar, Ganesh Nagar Rd, Nanded 431602** and their contact details are Office Number: 9890020084 and Email ID: shrisairajenterprises0@gmail.com with PAN registration No. ADRPH7277C and GST No. 27ADRP7277C2Z7 to act as a Licensed Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

**1. Fire Fighting and Sprinkler System:**

**M/s. Shri Sairaj Enterprises** shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **04.01.2025 to 03.01.2027**

**Hatyal**  
**Kiran**

Digitally signed  
by Hatyal Kiran  
Date: 2025.01.08  
21:10:48 +05'30'

Asst Director

**HATKAR**  
**RAJU**  
**HIRAMAN**

Digitally signed  
by HATKAR  
RAJU HIRAMAN  
Date: 2025.01.07  
15:53:18 +05'30'

**SANTOSH**  
**SHRIDHAR**  
**WARICK**

Digitally signed by  
SANTOSH SHRIDHAR  
WARICK  
Date: 2025.01.09  
10:59:58 +05'30'

**( S S Warick )**  
**Director**

**Maharashtra Fire Service**

Digital Signature of Authorized Person to sign Form A or Form B

**Note:**

\* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.



Authorised By Govt. Of Maharashtra Fire Services Mumbai

# SHRI SAIRAJ ENTERPRISES

TOTAL SOLUTIONS FIRE & SAFETY ENGINEERS

**RAJU HATKAR**

(Fire Engg. & Ind. Safety Mgt.)

## Fire Audit Survey Report

By Govt.Of Maharashtra Approved License Agency.

REF.SSE/FASR/26-27/04-16

DATE:-21/04/2026

License No. MFS/LA/F-04

Name And Address Of The Building:-

M.S.P Mandals. Shri Shivaji College.  
At-Basmat Road,Parbhani Tq.Dist-Parbhani.

Type Of Occupancy:-

Educational Building.

Use Of Building:-

Administration & Teaching.

Building Type:-

Semi Govt.

(Govt./Semi.Govt./Private/Municipal/Trustee/Charity)

Fire Safety Directives Letter No.:-

Nil.

Date Of Inspection:-

18<sup>th</sup> April 2026.

Name Of The Inspecting Officer/Agency:-

Shri Sairaj Enterprises.

Name Of Building Incharge & Tel No.:-

Eknath G Deokar/8275332463.

Name Of Administrative Head:-

Dr.B.U.Jadhav.

Incharge /Dean Name & Tel No.:-

Dr.S N Keshatti/9422743448.

Name Of The Occupier Of The Building/Woner:-

M.S.P Mandals.

Plot Area:-

(Approx)69450.00 Sq.Mtr.

Total Built-Up Area:-

11080.00 Sq.Mtr.

Height Of The Building/Shed:-

10.60 Mtr.

Year Of Construction Of Building:-

55/56Years.

Total Number Of Floors:-

Ground Floor + 3<sup>rd</sup> Floor.

**For.Shri Sairaj Enterprises**

HATKAR RAJU  
HIRAMAN

Digitally signed by  
HATKAR RAJU  
HIRAMAN  
Date: 2026.04.21  
13:23:08 +05'30'

License No : MFS/LA/F-04

01Page



Authorised By Govt. Of Maharashtra Fire Services Mumbai

# SHRI SAIRAJ ENTERPRISES

TOTAL SOLUTIONS FIRE & SAFETY ENGINEERS

RAJU HATKAR

(Fire Engg. & Ind. Safety Mgt.)

REF.SSE/FASR/26-27/04-16

DATE:-21/04/2026

Name And Address Of The Building:-

M.S.P Mandals Shri Shivaji College.  
At-Basmat Road.Parbhani Tq Dist-Parbhani.

Sr. No.	Minimum Standard For The Fire Prevention & Fire Safety	Requirement As Per NBC 20216	Provided At Site	Remarks
01	Access To The Building -Road Width -Gate Width -Internal Road Width	20Ft. 10Ft. N/A	10Ft. 05Ft. N/A	Meet Requirements Meet Requirements N/A
02	Means Of Egress A. Number Of Staircase - Upper Floor - Basement B. Width Of Staircase - Upper Floor - Basement C. Protection Of Exits - Fire Check Door - Pressurization D. No. Of Continuous Staircase To Terrace E. Stair Case Lobby F. Width Of Corridor	02  3.0Mtr  3.0 Mtr  01	01  2.12Mtr  2.12Mtr  01	Meet Requirements  Meet Requirements  Meet Requirements  Meet Requirements
03	Fire Extinguishers -Total No. -Types -ISI Marking  -Type -ISI Marking	50 ABC IS:15683 10 CO2 IS:15683	30 ABC IS:15683 05 CO2 IS:15683	Meet Requirements  Meet Requirements
04	Fire Pump Set A. No.Of Total Pump Set - Main Electrical Driven Pump - Jockey Pump -Booster Pump	06 2250Lpm 180Lpm 450Lpm	00 Not Provide Not Provide Not Provide	Meet Requirements
05	Water Storage Tank A- No. Of Total Storage Tank -Over Head Water Tank -Underground Water Tank	06 40000 Ltr 50000 Ltr	02 40000Ltr 50000Ltr	Meet Requirements

For -Shri Sairaj Enterprises

HATKAR RAJU  
HIRAMAN

Digitally signed by  
HATKAR RAJU HIRAMAN  
Date: 2026.04.21  
13:25:21 +05'30'

Authorised Signatory Stamp With Seal

Page-02.



Authorised By Govt. Of Maharashtra Fire Services Mumbai

# SHRI SAIRAJ ENTERPRISES

**TOTAL SOLUTIONS FIRE & SAFETY ENGINEERS**

**RAJU HATKAR**

(Fire Engg. & Ind. Safety Mgt.)

Sr.No.	Fire Safety Checklist Description	Date:-21/04/2026 Remark
01	Building Open Spaces	
A	East	10000 Sq.Mtr.
B	West	Not Available
C	South	Not Available
D	North	15000 Sq.Mtr
E	Nos.Of Exit ( Gate/Door/Terrace,Etc)	Gate-01 Nos.
F	Exit Width	05 Mtr.
G	Nos.Of Staircase & Its Width	02, 2.12Mtr
H	Nature Of Flooring In Exit Route	02
I	Partitions If Any	Yes
J	Material Use For Partitions	Concreat Plates
02	Basement Utility	Not Available
03	Material Stored If Any In Basement	Not Available
04	Total Nos.Of Rooms/Floor	Ground Floor, Rooms-12
05	Total Nos.Of Rooms In Building	30
06	Nos. Of Toilet Blocks	07
07	Exterior Facading/Cladding Of Building-Glass,ACP Facading Etc.	Not Available
08	Over Head Water Tank Capacity	20000 Ltr
09	Underground Water Tank Capacity	40000 Ltr
10	Building Inetrior Nature	Cement
11	Nos.Of Lifts With Capacity	Not Available
A	Passanger Lift	Not Available
B	Stratcher Lift	Not Available
C	Fire Lift	Not Available
D	Any Other Lifts	Not Available
12	Electrical Wiring /installation Audit/Electrical Inspectors-	Electrical Audit
13	Annual Test Reporte-Copy	Yes
14	Interior Location	Not Available
15	Canteen/Pantry/Kitchen Location & Area	1500 Sq.Mtr.
16	Which Fuel Use /Nos. Of Cylinder & Location	LPG /25 Nos.Cylinder/Kitchen
17	Any Other Assemble Area Location	Not Available
18	Store Room Location	Near Hall No.20

For.Shri Sairaj Enterprises

HATKAR RAJU  
HIRAMAN

Digitally signed by  
HATKAR RAJU HIRAMAN  
Date: 2026.04.21  
13:26:44 +05'30'

License No : MFS/LA/F-04

03 Page

# SHRI SAIRAJ ENTERPRISES

TOTAL SOLUTIONS FIRE & SAFETY ENGINEERS

RAJU HATKAR

(Fire Engg. & Ind. Safety Mgt.)



Fire Safety Checklist		Date:-21/04/2026
Sr.No.	Description	Remark
19	Store Room Area & Storage Type	90.90 Sq.Mtr/Stationary
20	Transformer / Generator Location With Capacity	Near Physics Department/ 19Kwa
21	Air Conditioning Type Window /Spilt/Central Etc.	Spilt
22	Building Utilities	Hostel & School
23	Nos. Of Cinema Theaters/Hall/Operation Theater	03
24	Nos. Of Seating Arrangement/Beds.	400 Nos.Seat
25	Nos.Of Max Occupancies In Building	One
26	Type Of Material Store In Store Room	Stationary
27	Total Nos. Of Employe	249 Nos.
28	Nos. Of Staff Shift Wise	Not Available
29	Permssion & Approval	Not Available
30	Weather Building Plan Sanctioned From Compentent Authority/Govt.	Yes Approved FromLocal Authority
31	Weather Final Noc Obtained IF YES SUBMIT COPY	YES, Approved From Local Authority
32	Building Completion Certificate Obtained - If Yes- Submit Copy-	Yes Available
33	Fire Fighting Installation Details	No.
34	Active Fire Protection -	
1	Weather Fixed Fire Fighting System (Riser + Down Comer) Installed-	Not Available
2	Fire Smoke Detectors/Mcp/Pa System Installed-	Not Available
3	Special Public Address System Installed If Any-	Not Available
4	If Yes Is It In Operating/Working Condition-	Not Available
5	Fire Fighting Pump Details Electric/ Diesel, Output, Hp, Head, Etc.-	
A	Main Pump-	Not Available
B	Jockey Pump	Not Available
C	Sprinkler Pump	Not Available
D	Stand By Pump	Not Available
E	Diesel Pump	Not Available
F	Booster Pump - 450 lpm	Not Available
6	Emergency Backup Arrangement	Yes
7	Whether Fire System & Emergency Lightning Attached To Emergency Backup	Not Available

For-Shri Sairaj Enterprises

HATKAR RAJU  
HIRAMAN

Digitally signed by

HATKAR RAJU

HIRAMAN

Date: 2026.04.21

13:27:37 +05'30'

License No : MFS/LA/F-04

04 Page



Authorised By Govt. Of Maharashtra Fire Services Mumbai

# SHRI SAIRAJ ENTERPRISES

**TOTAL SOLUTIONS FIRE & SAFETY ENGINEERS**

**RAJU HATKAR**

(Fire Engg. & Ind. Safety Mgt.)

Fire Safety Checklist		Date:-21/04/2026
Sr.No.	Description	Remark
8	Fire Fighting Water Tank Capacity	Not Available
9	If Yes Date Of Last Testing	Not Available
10	no. Of Location Of Fire Extinguishers & Type Of Extinguisher & Last Inspected Date	Location-1, abc powder
G	Qualification / Experience-	
11	Refuge Area If Any Location Area, etc-	No.
12	Assembly Point Identified On Ground - Location	No
13	Whether Adequate Fire & Safety Directional Signages Boards Installed - Yes/No-	Not Available
14	No. Of Type Of Smoke Masks	Not Available
15	Whether Assembly Point Marked Clearly , yes/no -	Not Available
16	No. Of Staff Trained For Basic Fire Fighting	20
35	Other Information	
1	Whether Fire Emergency Instructions Board Installed On Every Floor	Yes
2	Fire Staff Provided If Yes /No	Yes Fire Staff Provided With 10Nos.
3	No. Of Staff Trained For Basic Fire Fighting	20
4	Security Staff Trained	Yes,
36	Fire Prevention & Awareness Measures	
1	Fire Mock Drill Conducted If Any - Yes/ No	Yes
2	if yes, date of recent drill-submit report	Not Available
3	Weather Evacuation Drill Conducted, Yes/No. If Yes Indicate Periodicity	Not Available
4	Responsible Person In Case Of Emergency - Name, Address, Contact No.	Dr.S.N.Keshatti.At-Parbhani Dist-Parbhani,Mo-
5	is the fire officer employed	No
6	safety officer/ security officer	No
7	refuge area if any location area, etc	No
8	Assembly Point Identified On Ground- Location	No
9	List Of Other Staff Trained For Handling Fire Related Emergencies	Yes
10	Whether Adequate Fire & Safety Directional Signages Boards Installed- (Yes/No.)	No
11	Is Licensed Agency Appointed For Six Monthly Inspection - Yes/No.	Yes
12	Name And Details Of Licensed Agency	Shri Sairaj Enterprises
13	Additional Observations, If Any	Not Available
14	Recommendations If Any	Not Available

For-Shri Sairaj Enterprises  
**HATKAR**  
**RAJU**  
**HIRAMAN**  
 Digitally signed by  
 HATKAR RAJU  
 HIRAMAN  
 Date: 2026.04.21  
 13:28:35 +05'30'  
 License No : MFS/LA/F-04

05Page



Authorised By Govt. Of Maharashtra Fire Services Mumbai

# SHRI SAIRAJ ENTERPRISES

**TOTAL SOLUTIONS FIRE & SAFETY ENGINEERS**

**RAJU HATKAR**

(Fire Engg. & Ind. Safety Mgt.)

Fire Safety Checklist		Date:-21/04/2026
Sr.No.	Recommendation In Respect Of Adequate And Effective Installation Of Fire Safety Measures-	
01	Marginal Spaces Shall Be Kept Free From Obstruction All The Time. Remove All The Grass From Side Marginal Spaces.	
02	Corridor, Exit Way, Escape Route Shall Be Free From Any Obstruction .	
03	Circuit Breaker Arrangement That Is MCB,ELCB, Etc. Shall Be Provided As Per The Load Capacity	
04	Electrical Audit Should Be Done Immediately	
05	Manual Fire Alarm System Shall Be Provided In All The Premises	
06	Automatic Detection Shall Be Provided At Appropriate Places. Eg. Smoke Detector, Heat Detector beam Detector.	
07	Do The Refilling Of First Aid Fire Fighting Arrangement Like Fire Extinguishers Which Is Installed In Your Premises, If The Due Date Has Expired.	
08	Please Provide Minimum 08 No. ABC Type Fire Extinguisher of Capacity 6 Kg Capacity & 01 No. CO2 Type Fire Extinguisher Of Capacity 4.5 Kg Capacity In The At Appropriate Places	
09	Please Provide Minimum 0 No. Mechanical Foam Type Fire Extinguisher of Capacity 9 Liter capacity & 00 No. Mechanical Foam Type Fire Extinguisher of Capacity 45 Litre Capacity In The At Appropriate Places.	
10	First Aid Fire Fighting Arrangement like Hose Reel Shall Be Provided At Appropriate Places. The First Aid Hose Reel Shall Be Connected Directly To Downcomer Line Of 100 mm Dia And Diameter Of The Hose Reel Not Less Than 19mm Confirming to IS:884:1985 & NBC-2016 Part IV Clause 5.11(B), 4(17)	
11	Over Head water Storage Tank: -10,000 Liters Capacity For Firefighting With 01 No. Electric Booster Pump of LPM Near UG Tank, Diesel Fire Fighting Pump 1620 lpm 01 no.	
12	Fire Brigade Connection For Static Water Tank & For Hydrant Sytem Should Be Provided At Mian Entrance Gate.	
13	Electrical Services Are To Be Provided Per Annexure C1.12 (NBC Part 4).	
14	Electrical Main Switch Shall Be Easily Visible Accessible & Safe Location	
15	It Shall Be Ensured That Security Staff Of The Building Is Trained In Handling Fire Fighting Equipments & Fire Fighting.	
16	Cautionary Boards Such As "DANGER" , "NO SMOKING", "EXIT", "FIRE ESCAPE", Strategic Location To Guide The Occupants In Case Of Emergency. The Signs Shall Be Of Florescent Type And Shall Glow In Dark	
17	Fire Resistance Doors At Near Emergency Exit	
18	Emergency Lights Shall Be Provided In All The Corridors, Passage Ways ,Etc.	
19	FRLS (Fire Retardant Low Smoke) Cables Shall Be Used For All Installations.	
20	All The Fire And Life Safety System & The Equipment Shall Be Installed By Approved License Agency:	
21	House-Keeping To Be Maintained As Per Annexure C (NBC Part 4).	
22	No Inflammable Liquid Shall Be Stored In This Building Other Than Medical Use	
23	In Addition To The Above, All Provision Under The National Building Code 2016 Shall Be Strictly Adhered.	

For-Shri Sairaj Enterprises

HATKAR

Digitally signed

by HATKAR

RAJU

RAJU HIRAMAN

HIRAMAN

Date: 2026.04.21

13:29:30 +05'30'

License No : MFS/LA/F-04

Page-06